



- 1) Oil Conservator
- 2) 2) Magnetic oil level indicator (without contact) - L=124
- 3) Dehydrating breather (G.D-603)
- 4) HV Bushing 30 NF 250 (GD-334) (DIN 42531)
- 5) LV Bushing DT1/630 (GD-333) (DIN 42530)
- 6) Off circuit tap changer
- 7) Lifting lugs for complete transformer and active part
- 8) Terminal sheet
- 9) Rating Plate
- 10) Oil drain and down sampling device(DIN 42551)
- 11) Earthing screw M12
- 12) Pulling lug $\phi 30$
- 13) Oil thermometer pocket -1"
- 14) Drain for conservator
- 15) Filling cap for conservator

Voltage ratio: $33 \pm 2*2.5 \% / 0.4 \text{ KV}$
 Vector group: Dyn1
 Frequency: 50 Hz
 Cooling mthod: ONAN
 Transformer color: RAL7032

Weights :

Core & Winding : 588 kg
 Untanking : 748 kg
 Oil : 362 kg
 Total : 1360 kg

گنابند سرول شمشاد
 ۱۳۹۶/۳/۲۸
 مهندسی و طراحی

Comment :				Tolerances according to: DIN ISO 2768-C	Superficial Tolerances: DIN ISO 1302	Ordered by: نرمال یهینه	Power: 315 kVA R30	
				95	Date	Name	Title: Outline drawing	
				Dsgn	8.15	Rezaee		
				Cntrl	8.22	Yousefi		
				Appr	8.23	Shajeri		
				Kooshkan Transformers			Drawing no.: KTD017906	Scale: 1/21
1	Place of part 13	96.03.27	Rezaee				Ref. no.: KTB1377	Page: 1/1
Index	Changes	Date	Name	Appr				